



Arlington Industries, Inc.

1 Stauffer Ind. Park - Scranton, Pa. 18517

800-233-4717 Fax : 570-562-0646

www.aifittings.com - E-MAIL : sales @ aifittings.com

Manufacturers of Quality Electrical Products



Installation Instructions For : GB5 (Zinc) & GBB5 (Bronze) GROUNDING BRIDGE

- Locate GB5 / GBB5 To Accept Grounding Electrode Conductor From Service Equipment
- Install GB5 / GBB5 To Surface (Screws Not Provided)
- Install Grounding Electrode Conductor From Service Equipment at Lay-In Lug using #6 - #2 AWG Solid Copper*, #6 - #2 Stranded Copper or Aluminum***
- Install Bonding Conductor from Utilities, #14 - #6 AWG Solid Copper**, #4 AWG Solid Copper*, #14 - #4 AWG Stranded Copper***, or #6 - #4 Stranded Aluminum***
- Install Cover W / Screw Provided

NOTE: All Wiring Must be According to NEC, State and Local Codes.

If you have any questions or if parts are missing Please call our Customer Service Department at 1-800-233-4717. Do not call or return this product to your local store or distributor.

*50 In-Lb Torque **30 In-Lb Torque ***20 In-Lb Torque

Contents:

- (1) Cover
- (1) Grounding Bridge
- (1) #10-24 x 1" Screw
- (4) 1/4-20 x 5/8" Screw
- (1) 5/16-18 x 3/4" Screw

